



# STANDBY GENERATOR ACCESSORIES

## Maintenance Kits

### Air-Cooled Engines


- Model 5661
- Model 5662
- Model 5663
- Model 5664
- Model 5665



### DESCRIPTION

Preventative maintenance is a necessity for all standby generators. The Air Cooled Scheduled Maintenance kits offer all the hardware necessary to perform a complete maintenance on Guardian air-cooled generators. Oil will need to be purchased separately based upon the recommendations listed. Maintenance is recommended at every 200 hours or 2 years. If running in a dusty environment, more frequent maintenance may be required. Further maintenance details can be found in the generator owner's manual.

### OIL RECOMMENDATIONS



### KIT CONTENTS

Kit Model	5661	5662	5663	5664						5665
Unit Size	7kW	8kW	10kW	12kW	13kW	14kW	16kW	17kW	18kW	20kW
Air Filter	•	•	•	•	•	•	•	•	•	•
Pre-Cleaner			•	•	•	•	•	•	•	•
Oil Filter	•	•	•	•	•	•	•	•	•	•
Spark Plug(s)	1	1	2	2	2	2	2	2	2	2
Spark Plug Wrench	•	•		•	•	•	•	•	•	•
Oil Funnel	•	•	•	•	•	•	•	•	•	•
Chamois	•	•	•	•	•	•	•	•	•	•
Reminder Sticker	•	•	•	•	•	•	•	•	•	•

\*Contents of kits may vary



Generac Power Systems, Inc. • P.O. Box 297, Whitewater, WI 53190 • [guardiangenerators.com](http://guardiangenerators.com)

©2008 Generac Power Systems, Inc. All rights reserved. All specifications are subject to change without notice. Bulletin 0177270SBY/Printed in U.S.A. 04.08, rev. 05.08